Certificate

Certificate no. **TU 722340006 01**

License Holder:
UAB "SOLITEK CELLS"
Mokslininku str. 6ª
Vilnius 08412
Lithuania

Manufacturing Plant(s):
Refer to the latest revision of Appendix 2, List of Factories.

Test report no.: USA-323440007.001 **Client Reference:** Vilius Aleknavicius
Tested to: ANSI/UL 61730-1: 2017, ANSI/UL 61730-2: 2017

Certified Product: Photovoltaic Modules

Model Designations:
BLACKSTAR B.108 XXX Wp (XXX=370 to 445, in step of 5W)

Maximum System Voltage:	1000 V DC
Safety Application Class:	Class II
Max Overcurrent Protection Rating:	20 A
Fire Type:	Type 29

All models listed above are Glass/Glass Bifacial monocrystalline-Si modules with 108 cells.

Electrical ratings are provided at Standard Test Conditions (STC),
1000 W/m^2, AM 1.5 spectrum, 25^{o}C cell temperature.

Appendices: 1, 1-7 2, 1

Licensed Test Mark:

PTL US CERTIFIED

Date of Issue:

13 November 2023